

TRIPPLICATE
Owner's Copy

Page 1 of 1

Owner's Well No. 02-1

Date Work Began 3/8/2002, Ended 3/11/2002

Local Permit Agency Nevada Co Environmental Health

Permit No. 6605

STATE OF CALIFORNIA

WELL COMPLETION REPORT

Refer to Instruction Pamphlet

No. 787091

Permit Date 3/8/2002

DWR USE ONLY --- DO NOT FILL IN

STATE WELL NO./STATION NO.


LATITUDE

LONGITUDE

APN/TRS/OTHER

GEOLOGIC LOG

ORIENTATION (✓)	✓ VERTICAL	HORIZONTAL	ANGLE	(SPECIFY)
DEPTH FROM SURFACE	DRILLING METHOD	AIR ROTARY	FLUID	DESCRIPTION
Ft. to Ft.				Describe material, grain, size, color, etc.
0	3	Top Soil		
3	50	Decomposed Greenstone		
50	100	Weathered Greenstone		
100	160	Greenstone w/Fractures		
160	220	Greenstone		



WELL OWNER

Name Gene Fleitas

Mailing Address 11279 Marjon Drive
Nevada City

CA 95959

CITY

STATE ZIP

WELL LOCATION

Address 11190 Shire Court

City Grass Valley CA 95949-
County Nevada

APN Book 25 Page 390 Parcel 39

Township 15 N Range 8 E Section 29

Latitude

DEG. MIN. SEC.

LOCATION SKETCH

NORTH

DEG. MIN. SEC.

ACTIVITY (✓)

✓ NEW WELL

MODIFICATION/REPAIR
— Deepen
— Other (Specify)

DESTROY (Describe
Procedures and Materials
Under "GEOLOGIC LOG")

PLANNED USES (✓)

WATER SUPPLY
✓ Domestic Public
— Irrigation Industrial

MONITORING

TEST WELL

CATHODIC PROTECTION

HEAT EXCHANGE

DIRECT PUSH

INJECTION

VAPOR EXTRACTION

SPARGING

REMEDIATION

OTHER (SPECIFY)

WEST

EAST

SOUTH

Illustrate or Describe Distance of Well from Roads, Buildings, Fences, Rivers, etc. and attach a map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.

WATER LEVEL & YIELD OF COMPLETED WELL

DEPTH TO FIRST WATER 110 (Ft.) BELOW SURFACE

1

DEPTH OF STATIC WATER LEVEL 100 (Ft.) & DATE MEASURED 3/11/2002

ESTIMATED YIELD • 10 (GPM) & TEST TYPE Air

TEST LENGTH 4 (Hrs.) TOTAL DRAWDOWN 0 (Ft.)

May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 220 (Feet)
TOTAL DEPTH OF COMPLETED WELL 220 (Feet)

DEPTH FROM SURFACE		CASING (S)					
Ft.	Ft.	BORE-HOLE DIA. (Inches)	TYPE (✓)	MATERIAL / GRADE	INTERNAL DIAMETER (Inches)	GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)
0	20	10 5/8					
20	135	8 5/8					
0	95	✓		F-480	6"	CI 125	
95	135	✓		F-480	6"	CI 125	1/8"x3"

DEPTH FROM SURFACE		ANNULAR MATERIAL		
Ft.	Ft.	CEMENT (✓)	BENTONITE (✓)	FILL (✓)
0	20		✓	
20	25	✓		

ATTACHMENTS (✓)

- Geologic Log
- Well Construction Diagram
- Geophysical Log(s)
- Soil/Water Chemical Analysis
- Other

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.
NAME PETERS DRILLING & PUMP SERVICE INC.

(PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

P.O. Box 1546

ADDRESS

Signed

WELL DRILLER/AUTHORIZED REPRESENTATIVE

Grass Valley

CA

95945

CITY

STATE

ZIP

03/25/16

DATE SIGNED

456136

C-57 LICENSE NUMBER